

PROPOSED LAYOUT

APPLICATION FOR CONSTRUCTION PERMIT &
INSPECTION FORM FOR ON-SITE SEWAGE
MANAGEMENT SYSTEM

UNION COUNTY ENVIRONMENTAL HEALTH 46 HUGHES
STREET, SUITE B
BLAIRSVILLE, GA 30512

Permit Number: OSC14402481
Property Address: Whisper Cove
Owners Name: John & Laurie Carroll
Water Supply: Public

Permit Type: New System
Facility Type: Residence
Bedrooms/GPD: 3
Garbage Disposal: No

Linear Ft: 204' Quick 4 Plus HC

Trench Width (in): 36 "

Trench Depth (in): 24 "

Septic Tank Size: 1000 Gallons Pump Tank: 1000 Gallons Grease Trap: _____ Gallons

Distance Septic Tank From Well/Well Site: _____ Distance Drain Line From Well/Well Site: _____

Comments: Tanks must be 10' from structure & property lines, 50' from spring head & stream & must be above 1785 elevation line. Drain line must be 5' from property lines, 100' from spring & 15' from drainage.

Proposed Site Approved By: _____

Date: 10/27/22

See attached plat with septic & house site development areas noted.